

FAKRO Test Results Summary December 2012



AS4285 - Watertightness, Concentrated Load, Non-cyclonic & Cyclonic wind pressure test results

MODEL	IBA Test No.	Watertightness Test	Concentrated Load Test	Non-Cyclonic wind pressure Test	Cyclonic Wind pressure test
FAKRO FX48/46 69518 4032	4031S1	PASS	PASS	+5.0 kPa and -7.0 kPa	PASS
FAKRO FX48/46 69518 4032	6035S2				To BCA Table B1: -4.0 kPa PASS To AS1170.2/AS4285: -4.4 kPa PASS
FAKRO FV48/46 69618 0432	4031S2	PASS	PASS	+3.5 kPa and -3.0 kPa	PASS
FAKRO FV48/46 69618 0432	6035S1				To BCA Table B1: -2.0 kPa PASS To AS1170.2/AS4285: -2.2 kPa PASS
FAKRO FPP-3 LV 78/118	2012-082-S1	PASS	PASS	+4.5 kPa and -4.5 kPa	PASS

NOTE:

These results summarise the results of testing conducted by Ian Bennie & Associates at their NATA approved testing laboratory in Dandenong Victoria.

Full test results are kept on file.

